

**Part 1            General****1.1                Summary**

1. Unless otherwise indicated, follow the standards below when renovating a room or suite of rooms or for new constructions. All requirements outlined herein shall be reviewed with the McGill University Fire Prevention Office (FPO) and confirmed before the commencement of construction

**1.2                Design Requirement**

1. Clearly indicate items or equipment to be relocated. Indicate their actual and future location.
2. The fire pump relief valve must be a ¾ inches Clayton (Model 55L) no equivalence accepted.
  - .1 For inventory, quality control and maintenance purposes.

**1.3                Reference**

1. Comply with the requirements of the last edition of:
  - .1 Quebec construction code
  - .2 NFPA 20
  - .3 Municipal, provincial and federal applicable regulations

**END OF SECTION 21 30 00**